

THE SCHEDULE
FORM-A

(Form of application under Sub-Section (1) Sub-Section (2) of Section 4 of the Tamilnadu Public Buildings (Licensing) Act 1965.(Madras Act XIII of 1965) referred to in Rule 3 of the TamilNadu Public Buildings (Licensing) Rules 1996)

From

The Correspondent

St.Joseph's Matriculation School

S.F.No.71/2,71/3C,71/4,73/1, 73/12,34/7A,34/7B & 34/7C

Holy Mary Land

Andicheegurani Village,

Kalayarkovil Taluk, Sivaganga District

To

The Competent Authority


The Thasildhar

Kalayarkovil

Sir

I intend to use the building/to continue to use the existing Public building not at present used as a public building which is situated in the site of S.F.No.71/2,71/3C,71/4,73/1, 73/12,34/7A,34/7B & 34/7C,Holy Maryland, Andicheegurani in the ward or division /village/district of SIVAGANGA and specified in the statement enclosed as a public building for a period of 3 years and from the 27.07.2024 to 26.07.2027

2. The year of Construction and the present approximate Cost of Construction And the purpose for which it is to be used or is being used as a Public buildings Are also furnished in the statement accompanying this application.
3. I enclose a Chelan for Rs.1000/
4. I also enclose Certificate of Structural soundness in the prescribed form Furnished by the Engineer Shri. A.BALASUBRAMANIAN-PANEL ENGINEER GRADE-IA (Any amount), Approved by the SIVAGANGA District Collector thro Proceedings No.D.Dis.H2.12026/05, Dated 18.07.2005.


Signature of the owner of the bldg

Date:


- Enclosures:
1. Statement
 2. Original Chelan for Rs. 1000/-Towards the application fee.

STATEMENT ACCOMPANYING FORM-A


1. Door Number of the Building : S.F.No.71/2,71/3C,71/4,73/1, 73/12,
34/7A,34/7B & 34/7C
2. Location (st.No.ward.No.Name of : Andhichseegurani Village
Place ie Corporation/Municipality/ : Holy May Land
Panchayat/Panchayat Union/ : Kalayar Koil Block & Taluk
Contonment : Sivaganga District
3. Year of construction : 2017
4. App.Cost of Constn as per current rate : Rs. 3,50,00,000/-
5. Purpose for which this building is :
Being used or proposed to be used : To run a Matriculation school.
6. Purpose for which this bldg has
Hither to been used :do.....
7. Details of Constn of the bldg (parti
-Culars of the foundation and specfn
Of the various parts under)
 1. Foundation : RCC Footing with Mat
 2. Basement :do.....
 3. Superstructure : Brick work in CM
 4. Floor & roof are to be given : Ceramic tiled floor & RCC Roof
8. Period for which the License is
Required : 3 years
(27.07.2024 to 26.07.2027)
9. Number of Persons to be
Accommodated :
1500 Students

Date : 31.07.2024

A. BALASUBRAMANIAN,
B.E., M.I.E., F.I.V.,
CHARTERED ENGINEER,
PANEL ENGINEER GRADE - IA,
49, MUNESWARAN KOIL STREET,
KARAIKUDI - 630 001.
Mobile: 94422 37183


Signature of the Engineer

Certified that no addition or alteration has been made to the extg building or Portion of a bldg for which this application has been made. I undertake to obtain a fresh license, incase any addition or alteration is made to the extg bldg or portion of a bldg. I also undertake to obtain a fresh License, if the purpose for which the license was granted for the use of the building or a portion of the bldg originally is changed or altered subsequently.


Signature of the owner of the
Building.

FORM-B

(Form of Certificate of structural Soundness under Sub-Section (4) of the Section 4 of the Tamilnadu Public Buildings (Licensing) Act 1965 (TamilNadu Act 13 of 1965 referred to in rule 4 of the TamilNadu Public Buildings (Licensing) Rules 1966.)

I certify that I have inspected the building, mentioned in the statement and furnish below The salient technical features.


1. Foundation :
 - i. Depth below Ground Level : 210 cm
 - ii. Nature of Soil met with at foundation level : Medium soil
 - iii. Pressure at Foundation : 19.00 T/sqm
 - iv. Probable SBC of the treatment met with At foundation level. : 35.00 T/sqm
2. Superstructure :
 - i. Max. stress in the most critical section of

Masonry	: 16.00 Kg/sqcm
Concrete	: 31.50 Kg/sqcm
 - ii. Nature of masonry and Concrete and its Safe permissible stresses

Masonry	: 35.00 Kg/sqcm
Concrete	: 150.00 Kg/sqcm

The structural soundness of the building has been verified by me with reference to ISI Loading Standards 875 (Latest Version) and other relevant Indian Standards Code of Practice and I Declare that the Building is structurally Sound to be used as a Public Building for the purpose noted in the statement. A license may be Granted for the period of 3 years from the 27.07.2024 to the 26.07.2027, inclusive of this date.

Date : 31.07.2024


Signature of the Engineer.

A. BALASUBRAMANIAN,
B.E., M.I.E., F.I.V.,
CHARTERED ENGINEER,
PANEL ENGINEER GRADE - 1A,
49, MUNEESWARAN KOIL STREET,
KARAIKUDI - 630 001.
Mobile: 94422 37183

ANNEXURE TO FORM-B

(Statement to accompany the Certificate of structural soundness)

- | | | |
|-----|--|---|
| 01. | Location of the building
Door No, Street No and
Name of Place | : St. Joseph's Matriculation School
: S.F.No. 71/2, 71/3C, 71/4, 73/1, 73/12,
: 34/7A, 34/7B & 34/7C
: Holy Mary Land
: Andhichseegurrani Village
: Kalayarkovil Taluk
: Sivaganga District |
| 02. | Number, Age of the Building | : One-07 years |
| 03. | Short Description of structures
Steel/RCC framed or Load
Bearing walls | : RCC Framed Walls |
| 04. | Purpose for which the Building is
Certified for use | :
: To run a Matriculation school |
| 05. | The Period for which the building
Will be structurally sound | : 3 years
: (27.07.2024 to 26.07.2027) |
| 06. | Number of Persons to be
Accommodated | : 1500 Students |
| 07. | Remarks | : Form E & Declaration is
: Attached
: Each Floor—1159.91 Sqm each |

Date : 31.07.2024


Signature of the Engineer

A. BALASUBRAMANIAN,
B.E., M.I.E., F.I.V.,
CHARTERED ENGINEER,
PANEL ENGINEER GRADE - IA,
49, MUNESWARAN KOIL STREET,
KARAIKUDI - 630 001.
Mobile: 94422 37183

CHARTERED ENGINEER
PANEL ENGINEER GRADE - IA
49, MUNESWARAN KOIL STREET
KARAIKUDI - 630 001
Mobile: 94422 37183

FORM-C

(Form of Certificate of structural Soundness under Sub-Section (4) of the Section 4 of the Tamilnadu Public Buildings (Licensing) Act 1965 (TamilNadu Act 13 of 1965 referred to in rule 4 of the TamilNadu Public Buildings (Licensing) Rules 1966.)

I certify that I have inspected the building, mentioned in the statement and furnish below The salient technical features.

1. Foundation :

- | | | |
|------|---|---------------|
| i. | Depth below Ground Level | : 210 cm |
| ii. | Nature of Soil met with at foundation level | : Medium Soil |
| iii. | Pressure at Foundation | : 19.00 T/sqm |
| v. | Probable SBC of the treatment met with At foundation level. | : 35.00 T/sqm |

2. Superstructure :

- | | | |
|-----|--|------------------|
| i. | Max.stress in the most critical section of | |
| | Masonry | : 16.00 Kg/sqcm |
| | Concrete | : 31.50 Kg/sqcm |
| ii. | Nature of masonry and Concrete and its Safe permissible stresses | |
| | Masonry | : 35.00 Kg/sqcm |
| | Concrete | : 150.00 Kg/sqcm |

The structural soundness of the building has been verified by me with reference to ISI Loading Standards 875 (Latest Version) and other relevant Indian Standards Code of Practice and I Declare that the Building is structurally Sound to be used as a Public Building for the purpose noted in the statement. A license may be Granted for the period of 3 years from the 27.07.2024 to the 26.07.2027 inclusive of this date.

Date : 31.07.2024

Signature of the Engineer.

A. BALASUBRAMANIAN,
B.E., M.I.E., F.I.V.,
CHARTERED ENGINEER,
PANEL ENGINEER GRADE - 1A,
49, MUNEESWARAN KOIL STREET,
KARAIKUDI - 630 001.
Mobile: 94422 37183

STATEMENT TO ACCOMPANY THE OPINION REGARDING STRUCTURAL SOUNDNESS

- | | | |
|-----|---|---|
| 01. | Location of the building
Door No, Street No and
Name of Place | : St. Joseph's Matriculation School
: S.F.No. 71/2, 71/3C, 71/4, 73/1, 73/12,
: 34/7A, 34/7B & 34/7C
: Holy Mary Land
: Andhichseegurrani Village
: Kalayarkovil Taluk
: Sivaganga District |
| 02. | Number, Age of the Building | : One— 07 years |
| 03. | Number of Stories | : GF to SF only considered |
| 04. | Short Description of structures.
Steel/RCC framed or Load
Bearing walls | : RCC Framed walls |
| 05. | Purpose for which the Building is
Certified for use | : To run a Matriculation school. |
| 06. | The Period for which the building
Will be structurally sound | : 3 years
: (27.07.2024 to 26.07.2027) |
| 07. | Number of Persons to be
Accommodated | : 1500 Students |
| 08. | Remarks | : Form E & Declaration is
: Attached
: Each Floor—1159.91 Sqm each |

Date : 31.07.2024

Signature of the Engineer

A. BALASUBRAMANIAN,
B.E., M.I.E., F.I.V.,
CHARTERED ENGINEER,
PANEL ENGINEER GRADE - 1A,
49, MUNESWARAN KOIL STREET,
KARAIKUDI - 630 001.
Mobile: 94422 37183

STATEMENT TO ACCOMPANY THE OPINION REGARDING STRUCTURAL SOUNDNESS
A. BALASUBRAMANIAN
B.E., M.I.E., F.I.V.
CHARTERED ENGINEER
PANEL ENGINEER GRADE - 1A
49, MUNESWARAN KOIL STREET
KARAIKUDI - 630 001
MOBILE: 94422 37183

FORM- E

{Form of report to be made to the competent authority by inspecting authorities or officers Appointed under Other Acts Under section 28 of the Tamilnadu Public Buildings (Licensing)Act 1965 (Madras Act XIII of 1965) referred to in rule 7 of the Tamilnadu Public Buildings (Licensing) Rules, 1966)}

1. Name and designation of inspecting authority or Officer appointed or having jurisdiction under Any other Act or Law : A.Balasubramanian., B.E., M.I.E, M.Sc,
: Panel Engineer Grade-1A (Any amount)
: Sivaganga District
2. Location of the Building inspected (Door No. Street Number, Name of Place ie Municipal Corporation/Municipality/Panchayat or : St.Joseph's Matriculation School
: S.F.No.71/2,71/3C,71/4,73/1,73/12,
: 34/7A,34/7B & 34/7C
: Holy Mary Land
: Andicheegurani Village
: Kalayarkoil Taluk
: Sivaganga District
3. Date of Inspection : 30.07.2024
: Date of issue of Certificate
: 31.07.2024
4. Purpose for which the building is used : To run a Matriculation School
5. Nature of defects noticed : Nil
6. Suggestions for rectifying defects : Nil
7. If in a dangerous condition, immediate Steps recommended to be taken : Legal aspects not considered
: Refer the SSC & Declaration etc
: Western side wall to be plastered.

Signature of the inspecting authority or
Officer appointed or having jurisdiction

A. BALASUBRAMANIAN,
B.E., M.I.E., F.I.V.,
CHARTERED ENGINEER,
PANEL ENGINEER GRADE - 1A,
49, MUNEESWARAN KOIL STREET,
KARAIKUDI - 630 001.
Mobile: 94422 37183

DECLARATION BY THE PANEL ENGINEER GRADE-1A (Any amount)

St. JOSEPH'S MATRICULATION SCHOOL
S.F.No.71/2,71/3C,71/4,73/1,73/12,34/7A,34/7B & 34/7C,Holy Mary Land
Andicheegurani Village, Kalayarkovil Taluk
Sivaganga District

This Report does not include any eventualities caused due to natural calamities.

We hereby advise that periodical repairs and renovations shall be carried out to the entire building Blocks regularly every year by intimating me thro writing.

Further necessary fire fighting equipments should be kept in the premises and should be trained for Operation. If any fire accident/mishap occurs we are not held responsible.

Structural alteration/deviation should not be carried out to a part of whole building without prior permission from me.

Emergency exits to be provided as per norms.

All electrical points, wiring/Gadgets has to be checked properly and to be maintained periodically- this Competent Engineer is not held responsible for electrical defaults & short circuits.

If any violation is found at a later stage after issue of this report we are not held responsible and this report gets cancelled. The lessee has to adhere the legal frame work and then only this Certificate is Valid.

Further this report covers the certified blocks & floors only-Legal aspects not considered. Hoardings are not been considered in this Certificate.

Date of Inspection: 30.07.2024

Date : 31.07.2024

Signature of the inspecting authority or
Officer appointed or having jurisdiction

A. BALASUBRAMANIAN,

B.E., M.I.E., F.I.V.,

CHARTERED ENGINEER,

PANEL ENGINEER GRADE - 1A,

49, MUNESWARAN KOIL STREET,

KARAIKUDI - 630 001.

Mobile: 94422 37183

Copy to

1. P.A. to the Collector- Sivaganga
2. R.D.O.—Devakottai

FORM D

FORM OF LICENCE UNDER SUB-SECTION (1) OF SECTION 6 OF THE TAMIL NADU PUBLIC BUILDINGS (LICENCING) ACT 1965 (TAMIL NADU ACT XIII OF 1965) REFERRED TO IN RULE '6' OF THE TAMILNADU PUBLIC BUILDING LICENCING RULES, 1966.

LICENCE NO : 18/2025

REGISTRATION NO : K.Dis A5/856/2025

Licence is hereby granted to The Correspondent, St. Joseph's Matriculation School, S.No. 71/2, 71/3C, 71/4, 73/1, 73/12, 34/7A, 34/7B, 34/7C Andichiurani Village, Nedungulam Group, Kalaiyarkovil Taluk, Sivagangai District for the purpose and in respect of the building specified in the statements below and subject to the conditions and for the period mentioned hereunder:-

The period of validity of the Licence shall be from 27.07.2024 To 26.07.2027.

Three Years. (3 Years)

STATEMENT TO ACCOMPANY THE LICENCE

Location of the Building, (Door No. Street Name, and Name of the Place)	Purpose for which the building is licensed to be used as a public building.	No.of persons to be accommodated
St. Joseph's Matriculation School, S.No. 71/2, 71/3C, 71/4, 73/1, 73/12, 34/7A, 34/7B, 34/7C Andichiurani Village, Nedungulam Group, Kalaiyarkovil Taluk, Sivagangai District	To run class rooms	1500 Nos



[Signature]
Tahsildar,
Kalaiyarkovil

[Signature]
26/6/25

To
The Correspondent,
St. Joseph's Matriculation School,
S.No. 71/2, 71/3C, 71/4, 73/1, 73/12, 34/7A, 34/7B, 34/7C
Andichiurani Village, Nedungulam Group,
Kalaiyarkovil Taluk, Sivagangai District